# TRIDONIC

## EM converterLED BASIC MH/LiFePO4 50 V

TRIDONIC

www.tridonic.com

BASIC series

#### Product description

- Self contained emergency lighting LED driver for manual testing
- For LED modules with a forward voltage of 10 54 V  $\,$
- SELV for output voltage < 60 V DC
- Low profile casing (21 x 30 mm cross-section)
- For luminaire installation
- Compatible with Tridonic`s LLE FLEX modules (ADV, EXC)
- Nominal lifetime up to 100,000 h
- 5 years guarantee (conditions at www.tridonic.com)

#### Properties

- Non maintained operation
- 1 or 3 h rated duration
- Operating time selectable with plug (duration link)
- Compatible with all dimmable and non-dimmable constant current LED driver (see chapter 5.4)
- 3-pole technology: 2-pole LED module changeover and delayed power switching for the LED driver
- Automatic shutdown of output if LED load is out of range
- Constant power output
- Maximum light output for all LED modules
- Electronic charge system
- Deep discharge protection
- Short-circuit-proof battery connection
- Polarity reversal protection for battery provided by 3-pole connector
- Automatic detection of the connected battery technology (NiMH or LiFePO<sub>4</sub> batteries)

#### Batteries

- High-temperature cells
- NiMH or LiFePO<sub>4</sub> batteries
- LA or 18650 cells
- 4-year design life for NiMH batteries
- 1-year guarantee for NiMH batteries
- 4 8 years design life for LiFePO<sub>4</sub> batteries
- 3 years guarantee for LiFePO<sub>4</sub> batteries
- LiFePO<sub>4</sub> batteries with Tridonic LiFeGuard
- For battery compatibility refer to chapter 7.1



Standards, page 6

Wiring diagrams and installation examples, page 7



# TRIDONIC


## SELV 🕆 🗉 🖤 🛇 []][ 🙆 🤇 Ə Ἐ̈́̈́̈́ ـ Ἐ̈́́́ 🛣 Rohs]

## EM converterLED BASIC MH/LiFePO4 50 V

**BASIC** series

## Technical data

Rated supply voltage	220 – 240 V
AC voltage range	198 – 264 V
Mains frequency	50 / 60 Hz
LED module forward voltage range	10 – 54 V
Output current	see chapter 5.3
Starting time	< 0.5 s from detection of emergency event
Overvoltage protection	320 V (for 48 h)
U-OUT (including open- / short-circuit and double load)	60 V
Max. open circuit voltage	60 V
Battery charging time	24 h <sup>®⊕</sup>
Ambient temperature range ta	-5 + 55 °C
Max. casing temperature tc	75 °C
Mains voltage changeover threshold	according to EN 60598-2-22
Mains surge capability (between L – N)	1 kV
Mains surge capability (between L/N – PE)	2 kV
Type of protection	IP20
Lifetime	up to 100,000 h
Guarantee (conditions at www.tridonic.com)	5 years
Dimensions LxWxH	179 x 30 x 21 mm



Note: LED driver supplied with duration link in 3 hours position. Remove duration link for 1 hour duration. Duration link must be set before battery and mains connection.

#### Ordering data

		· actuaging,	Packaging,	Weight
number	duration	carton	pallet	per pc.
89800575	1/3 h	10 pc(s).	1,600 pc(s).	0.07 kg
89800708	1/3 h	10 pc(s).	1,600 pc(s).	0.07 kg
89800576	1/3 h	10 pc(s).	1,600 pc(s).	0.07 kg
89800577	1/3 h	10 pc(s).	1,600 pc(s).	0.07 kg
	89800575 89800708 89800576	89800575 1/3 h   89800708 1/3 h   89800576 1/3 h	89800575 1/3 h 10 pc(s).   89800708 1/3 h 10 pc(s).   89800576 1/3 h 10 pc(s).	89800575 1/3 h 10 pc(s). 1,600 pc(s).   89800708 1/3 h 10 pc(s). 1,600 pc(s).   89800576 1/3 h 10 pc(s). 1,600 pc(s).

#### Specific technical data

Туре <sup>®</sup>	Battery technology	Rated duration	Typ. λ (at 230 V, 50 Hz)	Typ. output power	Mains cu	Mains current in charging operation			ower in charging o	operation
				P emergency	Initial charge	Fast recharge	Trickle charge <sup>®</sup>	Initial charge	Fast recharge	Trickle charge <sup>®</sup>
	NiMH	1 h	0.60C	1.5 W	17 mA	17 mA	17 / 12 mA	2.4 W	2.4 W	2.4 / 1.4 W
EM converterLED BASIC 202	NIMH	3 h	0.60C	1.5 W	18 mA	18 mA	18 / 12 mA	2.6 W	2.6 W	2.6 / 1.4 W
MH/LiFePO4 50V		1 h	0.60C	1.5 W	17 mA	17 mA	17 / 12 mA	2.1 W	2.1 W	2.1 / 1.4 W
	LiFePO <sub>4</sub>	3 h	0.60C	1.5 W	20 mA	20 mA	20 / 12 mA	2.9 W	2.9 W	2.9 / 1.4 W
	NiMH	1 h	0.60C	2.3 W	17 mA	17 mA	17 / 12 mA	2.4 W	2.4 W	2.4 / 1.4 W
EMconverterLED BASIC 202A		3 h	0.60C	2.3 W	18 mA	18 mA	18 / 12 mA	2.6 W	2.6 W	2.6 / 1.4 W
MH/LiFePO4 50V	LiFePO4	1 h	0.60C	2.3 W	17 mA	17 mA	17 / 12 mA	2.1 W	2.1 W	2.1 / 1.4 W
,	LIFeP04	3 h	0.60C	2.3 W	20 mA	20 mA	20 / 12 mA	2.9 W	2.9 W	2.9 / 1.4 W
	NiMH	1 h	0.60C	2.5 W	17 mA	17 mA	17 / 12 mA	2.4 W	2.4 W	2.4 / 1.4 W
EM converterLED BASIC 203	NIMH	3 h	0.60C	2.5 W	19 mA	19 mA	19 / 12 mA	2.9 W	2.9 W	2.9 / 1.4 W
MH/LiFePO4 50V	1:5-00	1 h	0.60C	2.5 W	20 mA	20 mA	20 / 12 mA	2.8 W	2.8 W	2.8 / 1.4 W
	LiFePO <sub>4</sub>	3 h	0.60C	2.5 W	24 mA	24 mA	24 / 12 mA	3.8 W	3.8 W	3.8 / 1.4 W
	N I:N AL L	1 h	0.65C	3.5 W	17 mA	17 mA	17 / 12 mA	2.4 W	2.4 W	2.4 / 1.4 W
EM converterLED BASIC 204 MH/LiFePO4 50V	NIMH	3 h	0.65C	3.5 W	20 mA	20 mA	20 / 12 mA	3.0 W	3.0 W	3.0 / 1.4 W
	LiFaDO	1 h	0.65C	3.5 W	20 mA	20 mA	20 / 12 mA	2.8 W	2.8 W	2.8 / 1.4 W
	LiFePO <sub>4</sub>	3 h	0.65C	3.5 W	25 mA	25 mA	25 / 12 mA	3.9 W	3.9 W	3.9 / 1.4 W

• EM = Emergency

 $^{\textcircled{0}}$  16 h battery charging time for 2 h emergency lighting function according to AS 2293.

<sup>®</sup> In case of NiMH batteries: Intermittent charge is used. Value 1 is for 4 min. charge on / Value 2 is for 16 min. charge off. In case of LiFePO<sub>4</sub> batteries voltage dependent constant current charging is used.

 $^{\textcircled{0}}$  12 h battery charging time for 2 h emergency lighting function when used with LiFePO<sub>4</sub> batteries.

# TRIDONIC

## ACCES-SORIES

## EMcLED Strain-relief set 240x43x30mm


#### Product description

- Optional strain-relief set for independent applications
- Transforms the LED driver into a fully class II compatible LED driver (e.g. ceiling installation)
- Easy and tool-free mounting to the LED driver, screwless cableclamp channels with strain-relief (240 x 43 x 30 mm)









Permissible cable jacket diameter 2.2 – 9 mm

## Ordering data

Туре	Article number	Packaging, carton	Packaging, pallet	Weight per pc.
EMcLED SR	28003813	10 pc(s).	1,260 pc(s).	0.08 kg

**Emergency lighting units** EM converterLED

#### RoHS



Test switch EM3

#### Product description

- For connection to the emergency lighting unit
- For checking the device function
- Plug connection
- Dielectric strength: 1,500 V AC for 60 seconds



#### Ordering data

Туре	Article number	Packaging, bag	Packaging, carton	Weight per pc.
Test switch EM 3	89899956	25 pc(s).	200 pc(s).	0.013 kg

## ACCES-SORIES

## Status indication green LED

#### Product description

- A green LED indicates that charging current is flowing into the battery
- Plug connection



#### Ordering data

Туре	Article number	Packagin bag	Packaging, Packaging, bag carton		
LED EM green, 1.0 m CON	89800269	25 pc(s).	200 pc(s).	per pc. 0.015 kg	
LED EM green, HO 1.0 m CON	89800271	25 pc(s).	200 pc(s).	0.015 kg	
LED EM green, 0.6 m CON	89800472	25 pc(s).	200 pc(s).	0.009 kg	
LED EM green, HO 0.6 m CON	89800473	25 pc(s).	200 pc(s).	0.009 kg	
LED EM green, 0.3 m CON	89800270	25 pc(s).	200 pc(s).	0.005 kg	
LED EM green, HO 0.3 m CON	89800272	25 pc(s).	200 pc(s).	0.005 kg	



**Extension Cable LiFePO4** 

#### Product description

- Extension cable for LiFePO, batteries
- Cable length 500 mm
- 3-pole plug connection



Ordering data					
Туре	Article number	Packaging, bag	Packaging, carton	Weight per pc.	
EXTENSION CABLE LiFePO4 500mm	28002461	10 pc(s).	200 pc(s).	0.01 kg	



## **Connection Cable NiMH**

## Product description

- Connection cable for NiMH batteries
- Cable length 500 mm
- 2-pole plug connection for batteries and 3-pole plug connection for LED driver



#### Ordering data

Туре	Article number	Packaging, bag	Packaging, carton	Weight per pc.
CONNECTION CABLE NIMH 500mm	28002462	10 pc(s).	200 pc(s).	0.015 kg

EM converterLED

#### 1. Standards

- EN 61347-1
- EN 61347-2-13
- EN 61347-2-7
- EN 55015
- EN 61000-3-2
- EN 61000-3-3
- EN 61547
- EN 60068-2-64
- EN 60068-2-29
- EN 60068-2-30EN 62384
- EN 62384
- according to EN 50172
- according to EN 60598-2-22

#### Meaning of marking 🔘

Double or reinforced insulation for built-in electronic LED drivers. The control gear relies upon the luminaire enclosure for protection against accidental contact with live parts.

#### 1.1 Glow-wire test

according to EN 61347-1 with increased temperature of 850 °C passed.

#### 1.2 Insulation and electric strength testing of luminaires

Electronic LED-drivers can be damaged by high voltage. This has to be considered during the routine testing of the luminaires in production.

According to IEC 60598-1 Annex Q (informative only!) or ENEC 303-Annex A, each luminaire should be submitted to an insulation test with 500 Vpc for 1 second. This test voltage should be connected between the interconnected phase and neutral terminals and the earth terminal. The insulation resistance must be at least 2 M $\Omega$ .

As an alternative, IEC 60598-1 Annex Q describes a test of the electrical strength with 1,500 Vac (or 1,414  $\times$  1,500 Vbc). To avoid damage to the electronic devices this test **must not be conducted**.

## 2. Thermal details and lifetime

#### 2.1 Lifetime

Average lifetime 50,000 hours under rated conditions with a failure rate of less than 10 %. Average failure rate of 0.2 % per 1000 operating hours.

#### Expected lifetime with NiMH batteries

EM converterLED BASIC 202	tc	65 °C	70 °C	75 °C
MH/LiFePO4 50V	lifetime	> 100,000 h	> 100,000 h	93,000 h
EM converterLED BASIC 202A	tc	65 °C	70 °C	75 ℃
MH/LiFePO4 50V	lifetime	> 100,000 h	> 100,000 h	94,000 h
EM converterLED BASIC 203	tc	65 °C	70 °C	75 °C
MH/LiFePO4 50V	lifetime	> 100,000 h	> 100,000 h	94,000 h
EM converterLED BASIC 204	tc	65 °C	70 °C	75 °C
MH/LiFePO4 50V	lifetime	> 100,000 h	> 100,000 h	90,000 h

#### Expected lifetime with LiFePO<sub>4</sub> batteries

EM converterLED BASIC 202	tc	65 °C	70 °C	75 °C
MH/LiFePO4 50V	lifetime	> 100,000 h	> 100,000 h	97,000 h
EM converterLED BASIC 202A	tc	65 °C	70 °C	75 °C
MH/LiFePO4 50V	lifetime	> 100,000 h	> 100,000 h	97,000 h
EM converterLED BASIC 203	tc	65 °C	70 °C	75 °C
MH/LiFePO4 50V	lifetime	> 100,000 h	> 100,000 h	89,000 h
EM converterLED BASIC 204	tc	65 °C	70 °C	75 °C
MH/LiFePO4 50V	lifetime	> 100,000 h	> 100,000 h	89,000 h

The emergency lighting LED driver is designed for a lifetime stated above under reference conditions and with a failure probability of less than 10 %.

The relation of tc to ta temperature depends also on the luminaire design. If the measured tc temperature is approx. 5 K below tc max., ta temperature should be checked and eventually critical components (e.g. ELCAP) measured. Detailed information on request.

#### 3. Installation / Wiring

#### 3.1 Wiring diagram

One or more LED modules with a total forward voltage of 10 to 54 V can be connected to the EM converterLED 50V module. These LED module(s), marked with "Emergency" are operated in emergency mode from the associated battery. In normal mains mode all LED modules are operated by the LED driver from the mains supply.

#### Use of the test switch:

For checking the device function press the test switch for a minimum of 3 seconds.


## **Emergency lighting units**

EM converterLED


#### EM converterLED BASIC with one LED module for non-maintained emergency operation

Not connected	L <sub>out</sub> L <sub>in</sub>	EM converterLED	LED driver + LED +	. +
Neutral Un-Switched Line	N L	BASIC	LED LED driver	LED Module Emergency
		switch Indicator P LED O		Battery

#### EM converterLED BASIC with a standard LED driver and one LED module for mains and emergency operation




#### EM converterLED BASIC with a standard LED driver and series operation of LED modules



## **Emergency lighting units**

EM converterLED


## EM converterLED BASIC with a standard LED driver and parallel operation of LED modules



#### 3.2 Wiring type and cross section


Solid wire with a cross section of  $0.5 - 1.5 \text{ mm}^2$ . Strip 8 - 9 mm of insulation from the cables to ensure perfect operation of terminals.

Wiring: LED module/LED driver/supply




#### 3.3 Battery connection

NiMH: Connection with extension




When using an EM converterLED in combination with a NiMH battery, order the CONNECTION CABLE NiMH 500mm seperately.


LiFePO,: Direct connection



LiFePO<sub>4</sub>: Connection with extension



3.4 Loose wiring



Loosen wire through twisting and pulling or using a  $\emptyset$  1mm release tool

#### 3.5 Wiring guidelines

- The LED terminals, battery, indicator LED and test switch terminals are classified as SELV (output voltage < 60 V DC). Keep the wiring of the input terminals separated from the wiring of the SELV classified terminals or consider special wiring (double insulation, 6 mm creepage and clearance) when these connections should be kept SELV.</li>
- The output to the LED is DC but has high frequency content, which should be considered for good EMC compliance.
- Separate LED leads from the mains and DALI connections and wiring for good EMC performance.
- Maximum lead length on the LED terminals is 3 m. For a good EMC performance keep the LED wiring as short as possible.
- Route the secondary wires (LED module) in parallel to ensure good EMC performance.
- Maximum lead length for the Test switch and Indicator LED connection is 1 m. Separate the test switch and Indicator LED wiring from the LED leads to prevent noise coupling.
- Battery leads are specified with 0.5 mm cross section and a length of 0.8 m
- Protect the wiring against short circuits to earth (sharp edged metal parts, metal cable clips, louver, etc.) to avoid the damage of the control gear.

To ensure that a luminaire containing LED emergency units complies with EN 55015 for radio frequency conducted interference in both normal and emergency mode it is essential to follow good practice in the wiring layout.

Within the luminaire route the switched and unswitched 50 Hz supply wiring as short as possible and keep it as far away as possible from the LED leads. Through wiring may affect the EMC performance of the luminaire.

Do not exceed the max. length of LED leads to the LED module. Note that the length of the EM converterLED leads to the LED module is added to the length of the leads from the LED driver to the EM converterLED module when conside-

ring the max. permitted lead length of the LED driver.

#### 3.6 Maximum lead length

LED 3 m (6 m loop)® Status indication LED 1 m Batteries 0.8 m

<sup>®</sup> Note: The length of LED leads to the LED module must not be exceeded. Note that the length of the EM converterLED leads is added to the length of the leads from the LED driver to the EM converterLED module when considering max. permitted lead length of the LED driver. Leads should always be kept as short as possible.

#### 3.7 Use of different phases

The use of different phases for switched line and unswitched line is allowed. When using different phases, the unswitched line must fail if the switched line fails. This is required to assure correct switching into emergency mode. It can be realised with a relay.

#### 3.8 Compatibility with LLE FLEX modules

The EM converterLED can be used within certain restrictions to operate constant voltage LED loads from the Tridonic LLE FLEX (ADV, EXC) product range. A certain minimum length of the LLE FLEX is required for correct operation.

Detailed information in the download area of the ST and PRO product pages at www.tridonic.com (EM converterLED manual).

#### 4. Mechanical values

#### 4.1 Housing properties

- Casing manufactured from polycarbonate.
- Type of protection: IP20
- Max. torque at the mounting screws: 0.8 Nm

#### 4.2 Mechanical data accessories

LED status indicator

- Green
- Mounting hole 6.5 mm diameter, 1 1.6 mm thickness
- Lead length 0.3 m / 0.6 m / 1.0 m
- Insulation rating: 90 °C
- Plug connection

#### Test switch

- Mounting hole 7.0 mm diameter
- Lead length 0.55 m
- Plug connection

#### Battery connection

- Plug connection 0.3 m
- Extension 0.5 m

## 5. Electrical values

## 5.1 Maximum loading of automatic circuit breakers

Automatic circuit breaker type	B10	B13	B16	B20	C10	C13	C16	C20	Inrush	n current
Installation Ø	1.5 mm <sup>2</sup>	1.5 mm <sup>2</sup>	1.5 mm <sup>2</sup>	2.5 mm <sup>2</sup>	1.5 mm <sup>2</sup>	1.5 mm <sup>2</sup>	1.5 mm <sup>2</sup>	2.5 mm <sup>2</sup>	l max	time
EM converterLED BASIC MH/LiFePO4 50V	90	130	130	130	180	260	260	260	10 A	120 µs

#### 5.2 Insulation matrix

	Mains	Switched Live	Battery, LED, Test switch, Indicator LED	LED driver
Mains	-	•	••	••
Switched Live	•	-	• •	••
Battery, LED, Test switch, Indicator LED	••	••	-	•
ED driver	••	••	-	-

Represents basic insulation

• • Represents double or reinforced insulation


When using a non-SELV LED driver insulate the battery, LED, test switch and indicator LED in the luminaire according to the U-OUT rating of the LED driver.

**Emergency lighting units** EM converterLED

#### 5.3 Typ. LED current/voltage characteristics


The LED current in emergency mode is automatically adjusted by the EM converterLED module based on the total forward voltage of the LED modules connected and the associated battery. The start of the LED in emergency mode does not result in a current peak.

EM converterLED BASIC 202 MH/LiFePO4 50V Article number: 89800575 NiMH battery, 2.4 V battery voltage 725 – 775 mA battery discharge current (tolerance) LiFePO<sub>4</sub> battery, 3.2 V battery voltage 550 – 590 mA battery discharge current (tolerance)




EM converterLED BASIC 203 MH/LiFePO4 50V Article number: 89800576 NiMH battery, 3.6 V battery voltage 810 – 870 mA battery discharge current (tolerance) LiFePO, battery, 3.2 V battery voltage

920 – 990 mA battery discharge current (tolerance)



EM converterLED BASIC 202A MH/LiFePO4 50V Article number: 89800708 NiMH battery, 3.6 V battery voltage 770 – 830 mA battery discharge current (tolerance) LiFePO<sub>4</sub> battery, 3.2 V battery voltage 880 – 950 mA battery discharge current (tolerance)




EM converterLED BASIC 204 MH/LiFePO4 50V Article number: 89800577

NiMH battery, 4.8 V battery voltage

825 – 885 mA battery discharge current (tolerance)

LiFePO<sub>4</sub> battery, 3.2 V battery voltage

1,315 – 1,415 mA battery discharge current (tolerance)



LED current at nominal battery voltage and min. battery discharge current

LED current at nominal battery voltage and max. battery discharge current

#### 5.4 LED driver compatibility


The EM converterLED emergency unit use 3 pole technology and is compatible with most LED drivers on the market, however it is important to check that the rating of the LED driver does not exceed the values specified below:

- The max. allowed output current rating of the associated LED driver is 2 A eff (current rating of the terminals of EM converterLED) and 2.4 A peak (current rating of switching relays of EM converterLED)
- The max. allowed inrush current rating of the associated LED driver is 60 A peak for 1 ms or 84 A for 255  $\mu s$  (inrush current rating of switching relay of EM converterLED)
- The max. allowed output voltage (U-OUT) of the associated LED driver applied to the EM converterLED output is 450 V (voltage withstand between adjacent contact of the single switching relay of the EM converterLED)
- The max. allowed LED load of the associated LED driver is 150 W in operation. The load must be an LED module.

Check compatibility with short function tests (duration of several seconds).

## 6. Functions

#### 6.1 Duration link selection



Emergency lighting LED driver supplied with duration link in 3 hours position.

The position of the link will only be read on first power up. If it is changed afterwards both the battery and mains supply must be disconnected for 10 seconds to enable the EM converterLED to read the new link position on reconnection of the battery and mains. It will lead to a false battery failure indication if the link is changed after installation without this reset.

#### 6.2 Status indication LED

System status is indicated by a green LED.

Note:

The status indication LED switches off if the battery does not reach the full capacity (3.6V battery voltage) within 20 – 24 hours. If this occurs disconnect the mains voltage and operate the device in emergency mode for approximately one hour. Afterwards apply the mains voltage again and recharge the battery for 24 hours. If the failure occurs again replace the battery.

## 7. Battery data

## 7.1 Battery selection

#### EM converterLED BASIC, 1 / 3 h

				Туре		erLED BASIC FePO4 50V		erLED BASIC .iFePO4 50V		erLED BASIC iFePO4 50V		erLED BASIC FePO4 50V
				Article no.	89800575		89800708		89800576		89800577	
				Duration	1 h	3 h	1 h	3 h	1 h	3 h	1 h	3 h
Technology and capacity	5	Number of cells	Туре	Article no.				Assignabl	e batteries			
	stick	1 x 2	Accu-NiMH 2A CON	28002316		•						
	stick	1 x 3	Accu-NiMH 3A CON	89800441				•		•		
NiMH 4.0 Ah	stick	1 x 4	Accu-NiMH 4A CON	89800442								•
LA cells	stick + stick	2 + 2	Accu-NiMH 4C CON	89800438								•
	remote box	1 x 3	Pack-NiMH 4Ah 3 CON	28001896				•		•		
	remote box	1 x 4	Pack-NiMH 4Ah 4 CON	28001897								•
	stick	1 x 1	Accu-LiFePO4 1A CON	28002317	•		•					
	stick	1 x 2	Accu-LiFePO4 2A CON	28002318		•			•		•	
	stick	1 x 3	Accu-LiFePO4 3A CON	28002320				•				
	stick	1 x 4	Accu-LiFePO4 4A CON	28002322						•		
	stick	1 x 5	Accu-LiFePO4 5A CON	28002325								•
	stick + stick	2 + 2	Accu-LiFePO4 4C CON	28002324						•		
LiFePO <sub>4</sub> 1.5 Ah	stick + stick	3 + 2	Accu-LiFePO4 5C CON	28002327								•
1.5 An 18650 cells	side by side	2 x 1	Accu-LiFePO4 2B CON	28002319		•			•		•	
	side by side	3 x 1	Accu-LiFePO4 3B CON	28002321				•				
	side by side	4 x 1	Accu-LiFePO4 4B CON	28002323						•		
	side by side	5 x 1	Accu-LiFePO4 5B CON	28002326								•
	remote box	1 x 2	PACK-LiFePO4 3.0Ah 2 CON	28003805		•			•		•	
	remote box	1 x 3	PACK-LiFePO4 4.5Ah 3 CON	28003806				•				
	remote box	1 x 4	PACK-LiFePO4 6.0Ah 4 CON	28003807						•		

## 7.2 Battery charge / discharge data

#### EM converterLED BASIC, 1 / 3 h, NiMH

	Туре		EM converterLED BASIC 202 MH/LiFePO4 50V		EM converterLED BASIC 202A MH/LiFePO4 50V		erLED BASIC FePO4 50V	EM converterLED BASIC 204 MH/LiFePO4 50V				
	Article no.	89800575		89800708		89800576		89800577				
	Duration	1 h	3 h	1 h	3 h	1 h	3 h	1 h	3 h			
	Initial charge				24	í h						
Battery charge time	Fast recharge	24 h										
	Trickle charge	continuously										
	Initial charge	110 – 150 mA	190 – 230 mA	110 – 150 mA	190 – 230 mA	110 – 150 mA	190 – 230 mA	110 – 150 mA	190 – 230 mA			
Charging current	Fast recharge	110 – 150 mA	190 – 230 mA	110 – 150 mA	190 – 230 mA	110 – 150 mA	190 – 230 mA	110 – 150 mA	190 – 230 mA			
charging current	Trickle charge	110 – 150 mA / 4 min. 0 mA / 16 min.	190 – 230 mA / 4 min. 0 mA / 16 min.	110 – 150 mA / 4 min. 0 mA / 16 min.	190 – 230 mA / 4 min. 0 mA / 16 min.	110 – 150 mA / 4 min. 0 mA / 16 min.	190 – 230 mA / 4 min. 0 mA / 16 min.	110 – 150 mA / 4 min. 0 mA / 16 min.	190 – 230 mA / 4 min. 0 mA / 16 min.			
Discharge current		725 – 775 mA	725 – 775 mA	770 – 830 mA	770 – 830 mA	810 – 870 mA	810 – 870 mA	825 – 885 mA	825 – 885 mA			
Charge volt	age range®	0.9 – 1.65 V per cell										
Discharge v	oltage range				1.65 – 1.05	V per cell						

 $^{\odot}$  The battery will be charged below 0.9 V. The EM converterLED will indicate a battery fault.

The emergency lighting LED driver will recharge the battery normally after running the test of 61347-2-7 CL 22.3 (abnormal operating conditions).

EM converterLED

#### EM converterLED BASIC, 1 / 3 h, LiFePO

	Туре		EM converterLED BASIC 202 MH/LiFePO4 50V		EM converterLED BASIC 202A MH/LiFePO4 50V		erLED BASIC FePO4 50V	EM converterLED BASIC 204 MH/LiFePO4 50V			
	Article no.	89800575		89800708		89800576		89800577			
	Duration	1 h	3 h	1 h	3 h	1 h	3 h	1 h	3 h		
	Initial charge 24 h										
Battery charge time	Fast recharge	charge 24 h									
	Trickle charge	le charge continuously and battery voltage controlled									
	Initial charge	115 – 155 mA	250 – 290 mA	115 – 155 mA	250 – 290 mA	250 – 290 mA	420 – 480 mA	250 – 290 mA	420 – 480 mA		
Charging current	Fast recharge	115 – 155 mA	250 – 290 mA	115 – 155 mA	250 – 290 mA	250 – 290 mA	420 – 480 mA	250 – 290 mA	420 – 480 mA		
	Trickle charge®	115 – 155 mA / 0 mA	250 – 290 mA / 0 mA	115 – 155 mA / 0 mA	250 – 290 mA / 0 mA	250 – 290 mA / 0 mA	420 – 480 mA / 0 mA	250 – 290 mA / 0 mA	420 – 480 mA / 0 mA		
Discharge current		550 – 590 mA	550 – 590 mA	880 – 950 mA	880 – 950 mA	920 – 990 mA	920 – 990 mA	1,315 – 1,415 mA	1,315 – 1,415 mA		
Charge voltage range <sup>∞</sup>				2.0 - 3.65 V							
Discharge v	oltage range				3.65 –	2.60 V					

<sup>®</sup> Automatic recharge when battery voltage falls below 3.4 V. Charger off (0 mA) when battery voltage exceeds 3.6 V.

Note: Battery protected against operation at excessive temperatures (charging stopped when battery cell temperature < 0 °C or > 60 °C).

The emergency lighting LED driver will recharge the battery normally after running the test of 61347-2-7 CL 22.3 (abnormal operating conditions).

 $^{\odot}$  The battery will not be charged below 2.0 V.

## 7.3 Accu-NiMH

Capacity 4.0 Ah		Capacity 4.0 Ah
International designation	HRMU 19/90	Battery voltage/cell
Battery voltage/cell	1.2 V	Cell type
Cell type	LA	Ambient temperature range
Case temperature range		to ensure 4 years design life
to ensure 4 years design life	+5°C to +50°C	tc point
Max. short term battery case temperature		Max. short term battery case temperature
(shorter than 1 month over the battery lifetime)	70 °C	(shorter than 1 month over the battery lifetime)
Max. number discharge cycles	4 cycles per year plus	Max. number discharge cycles

Max. storage time

#### 7.4 Accu-LiFePO4

		Capacity 1.5 All
Capacity 1.5 Ah		International designation
International designation	IFpR 19/66	Battery voltage/cell
Battery voltage/cell	3.2 V	Cell type
Cell type	18650	Case temperature range to ensure
Case temperature range to ensure		4 years design life
4 years design life	+5 °C to +55 °C	6 years design life
6 years design life	+5 °C to +45 °C	8 years design life
8 years design life	+5 °C to +35 °C	Max. short term battery case temperature
Max. short term battery case temperature		(shorter than 1 month over the battery lifetime)
(shorter than 1 month over the battery lifetime)	70 °C	Max. number discharge cycles
Max. number discharge cycles	50 cycles total	Max. storage time
Max. storage time	12 months	
	at +5 °C to +25 °C	

30 cycles during

at +5 °C to +25 °C

comissioning

12 months

Only use Tridonic batteries.

7.5 Accupack-NiMH

Max. storage time

Capacity 1.5 Ah

7.6 Accupack-LiFePO4

Comply with UN 38.3 and IEC 62133 (safety testing) protected against over charge, over discharge, charging at excessive temperatures, short-circuit and over current.

1.2 V

LAL

+40 °C

70°C

+5 °C to +35 °C

4 cycles during

comissioning 12 months

IFpR 19/66 3.2 V 18650

70°C 50 cycles total 12 months at +5 °C to +25 °C

+5 °C to +45 °C +5 °C to +35 °C +5 °C to +25 °C

4 cycles per year plus

#### 7.7 Safety incorporated



#### LiFeGuard

#### 7.7.1 Deep discharge protection

When the battery remains connected without charging for a long period of time after the battery cut off of the driver the battery voltage can still drop. To make sure the cells are not damaged by this voltage drop, the battery protection prevents the battery from further discharge below 2.0 V.

#### 7.7.2 Overcharge protection

If in case of an error or the use of a wrong driver the battery gets overcharged the battery protection will disconnect the battery from the driver at a voltage of 3.9 V. A discharge of the battery is still possible after the protection circuit was triggered to guarantee emergency operation.

#### 7.7.3 Short-circuit protection

In case of a short circuit the battery protection opens the connection to the driver and the output is therefore free of voltage. The output will be reactivated again when the short circuit is removed.

#### 7.7.4 Overtemperature protection

The battery is protected against temporary thermal overheating. If the temperature limit is exceeded the further charging of the battery is no longer possible. The temperature protection is activated below approx. 0 °C and above approx. +60 °C. The discharging of the battery is still possible to guarantee emergency operation.



Battery has built in thermal sensor for safe charging. Mount battery away from heat source.

Positioning of the thermal sensor see battery data sheet.

#### 7.8 Wiring batteries

To inhibit inverter operation disconnect the batteries by removing the connection at battery side.

For further informations refer to corresponding battery datasheet.

#### 7.9 Storage, installation and commissioning

Relevant information about storage conditions, installation and commissioning are provided in the battery datasheets.

#### 8. Miscellaneous

#### 8.1 Maximum number of switching cycles

 $\mathsf{EM}$  converterLEDs are tested with 50,000 mains switching cycles of the associated LED driver.

#### 8.2 Battery replacement

After a battery replacement and a subsequent full charge cycle (24 h) a duration test is mandatory to prove that with the new battery the rated duration is achieved.

#### 8.3 Mains-connected transformers

The EM converterLED does not contain mains-connected windings of transformers.

#### 8.4 Additional information

Additional technical information at <u>www.tridonic.com</u>  $\rightarrow$  Technical Data

Lifetime declarations are informative and represent no warranty claim. No warranty if device was opened.